

OSHA CITATIONS DON THRU 2ND QUARTER  
FY2014

Installation	Open Conf. Inspection Date	Inspection Type	Violation Type	Standard Cited	Description	NAVOSH Reference	Abatement Date	Max Private Sector Penalty
United States Department Of The Navy, Naval Facilities Engineering Command Naval Submarine Base New London Groton, CT 06439	10/18/2013	Complaint	Serious	1910.269(a)(2)(i)	<b>Electric Power Generation, Transmission, and Distribution. "General." "Training."</b> Employees shall be trained in and familiar with the safety-related work practices, safety procedures, and other safety requirements in this section that pertain to their respective job assignments. Employees shall also be trained in and familiar with any other safety practices, including applicable emergency procedures (such as pole top and manhole rescue), that are not specifically addressed by this section but that are related to their work and are necessary for their safety.	OPNAVINST 5100.23G, Chapter 11, Inspections and Investigations of Workplaces By Federal and State OSH Officials; Chapter 5, Prevention and Control of Workplace Hazards; Chapter 6, Training	12/31/2013 Close Case Date: (OPEN) Pending Informal Settlement	\$7,000
United States Department Of The Navy, Naval Facilities Engineering Command Naval Submarine Base New London Groton, CT 06439	10/18/2013	Complaint	Serious	1910.269(a)(2)(ii)D	<b>Electric Power Generation, Transmission, and Distribution. "General." "Training."</b> Qualified employees shall also be trained and competent in: The proper use of the special precautionary techniques, personal protective equipment, insulating and shielding materials, and insulated tools for working on or near exposed energized parts of electric equipment. Note: For the purposes of this section, a person must have this training in order to be considered a qualified person.	OPNAVINST 5100.23G, Chapter 11, Inspections and Investigations of Workplaces By Federal and State OSH Officials; Chapter 5, Prevention and Control of Workplace Hazards; Chapter 6, Training	12/31/2013 Close Case Date: (OPEN) Pending Informal Settlement	\$7,000

OSHA CITATIONS DON THRU 2ND QUARTER  
FY2014

United States Department Of The Navy, Naval Facilities Engineering Command Naval Submarine Base New London Groton, CT 06439	10/18/2013	Complaint	Serious	1910.303(b)(1)	<p><b>General requirements. Examination, installation, and use of equipment -- Examination.</b> Electric equipment shall be free from recognized hazards that are likely to cause death or serious physical harm to employees. Safety of equipment shall be determined using the following considerations: b(1)(i) Suitability for installation and use in conformity with the provisions of this subpart;; <b>Note to paragraph (b)(1)(i) of this section:</b> Suitability of equipment for an identified purpose may be evidenced by listing or labeling for that identified purpose; b(1)(ii) Mechanical strength and durability, including, for parts designed to enclose and protect other equipment, the adequacy of the protection thus provided; b(1)(iii) Wire-bending and connection space; b(1)(iv) Electrical insulation; b(1)(v) Heating effects under all conditions of use; b(1)(vi) Arcing effects; (b(1)(vii) Classification by type, size, voltage, current capacity, and specific use; and b(1)(viii) Other factors that contribute to the practical safeguarding of persons using or likely to come in contact with the equipment.</p>	OPNAVINST 5100.23G, Chapter 11, Inspections and Investigations of Workplaces By Federal and State OSH Officials; Chapter 5, Prevention and Control of Workplace Hazards	12/31/2013 Close Case Date: (OPEN) Pending Informal Settlement	\$7,000
United States Department Of The Navy, Naval Facilities Engineering Command Naval Submarine Base New London Groton, CT 06439	10/18/2013	Complaint	Serious	1910.303(h)(3)	<p><b>General. Over 600 volts, nominal --</b> Work space about equipment. Sufficient space shall be provided and maintained about electric equipment to permit ready and safe operation and maintenance of such equipment. Where energized parts are exposed, the minimum clear work space may not be less than 1.98 m (6.5 ft) high (measured vertically from the floor or platform) or less than 914 mm (3.0 ft) wide (measured parallel to the equipment). The depth shall be as required in paragraph (h)(5)(i) of this section. In all cases, the work space shall be adequate to permit at least a 90-degree opening of doors or hinged panels.</p>	OPNAVINST 5100.23G, Chapter 11, Inspections and Investigations of Workplaces By Federal and State OSH Officials; Chapter 5, Prevention and Control of Workplace Hazards	12/31/2013 Close Case Date: (OPEN) Pending Informal Settlement	\$7,000
<b>Total citations</b>	<b>Serious</b>	<b>Other</b>	<b>Repeat</b>					
4	4	0	0		2			